



Product Service

CERTIFICATE

No. Z2 13 01 80805 003

Holder of Certificate: EVEREXCEED INDUSTRIAL COMPANY LIMITED

UNIT E, 3/F, GOOD HARVEST CENTRE
33 ON CHUEN STREET, FANLING
N.T.
HONG KONG

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
[Mono-crystalline Silicon Photovoltaic (PV) Module]

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

68260901204A

Date, 2013-01-16


(Harry Shubo Zhang)



Page 1 of 2



CERTIFICATE
No. Z2 13 01 80805 003

Model(s): ESM220S-125, ESM225S-125, ESM230S-125, ESM235S-125, ESM240S-125, ESM245S-125, ESM250S-125, ESM255S-125, ESM260S-125, ESM265S-125, ESM270S-125; ESM155S-125, ESM160S-125, ESM165S-125, ESM170S-125, ESM175S-125, ESM180S-125, ESM185S-125, ESM190S-125, ESM195S-125, ESM200S-125; ESM80S-125, ESM85S-125, ESM90S-125, ESM95S-125, ESM100S-125

Parameters:

Rated output power at STC:	220 W, 225 W, 230 W, 235 W, 240 W, 245 W, 250 W, 255 W, 260 W, 265 W, 270 W; 155 W, 160 W, 165 W, 170 W, 175 W, 180 W, 185 W, 190 W, 195 W, 200 W; 80 W, 85 W, 90 W, 95 W, 100 W
Application class:	Class A
Fire safety class:	Class C
Max. system voltage:	1000V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, Cable and Connectors.

Tested according to: IEC 61215:2005
 EN 61215:2005
 IEC 61730-1:2004
 EN 61730-1:2007
 IEC 61730-2:2004
 EN 61730-2:2007

Production Facility(ies): 74315