



Product Service

Attestation of Conformity

No. N8 13 01 80805 004

Holder of Certificate: **EVEREXCEED INDUSTRIAL COMPANY LIMITED**

UNIT E, 3/F, GOOD HARVEST CENTRE
33 ON CHUEN STREET, FANLING

N.T.
HONG KONG

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
[Mono-crystalline Silicon Photovoltaic (PV) Module]**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 68260901204A



Date, 2013-01-16

Harry Shubo Zhang
(Harry Shubo Zhang)

CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity
No. N8 13 01 80805 004**Model(s):**

ESM220S-125, ESM225S-125, ESM230S-125,
ESM235S-125, ESM240S-125, ESM245S-125,
ESM250S-125, ESM255S-125, ESM260S-125,
ESM265S-125, ESM270S-125;
ESM155S-125, ESM160S-125, ESM165S-125,
ESM170S-125, ESM175S-125, ESM180S-125,
ESM185S-125, ESM190S-125, ESM195S-125,
ESM200S-125;
ESM80S-125, ESM85S-125, ESM90S-125,
ESM95S-125, ESM100S-125

Parameters:

Rated output
power at STC: 220 W, 225 W, 230 W,
235 W, 240 W, 245 W,
250 W, 255 W, 260 W,
265 W, 270 W;
155 W, 160 W, 165 W,
170 W, 175 W, 180 W,
185 W, 190 W, 195 W,
200 W;
80 W, 85 W, 90 W,
95 W, 100 W

Application class: Class A
Max. system voltage: 1000V DC
Test Laboratory: Yangzhou Opto-Electrical Products
Testing Institute
No. 10 West Kaifa Road, Yangzhou,
225009 Jiangsu, P. R. China

Construction: Framed, with Junction box, Cable
and Connectors.

**Tested
according to:**

EN 61730-1:2007
EN 61730-2:2007